


# WRRF Rehabilitation of Screened Final Effluent Pump Station

CIP 261008 | Contract 2000970

November 13, 2024, Operations and Resources Committee

Navid Mehram, Wastewater COO



# Executive Summary

## Rehabilitation of Screened Final Effluent Building

- 💧 The existing Screened Final Effluent (SFE) pump station is nearly 50 years old and in poor condition.
- 💧 The station has eight pumps with a total capacity of 135 million gallons per day (MGD), but the current usage is only ~25 MGD due to efficiency improvements and decommissioning of eight (8) incinerators.
- 💧 This project will replace the SFE pump station with equipment that matches the forecasted demand.
- 💧 The SFE will have additional treatment so that it can support additional plant processes reducing dependency on potable water improving overall resiliency.

# Project History

- Solicitation Energy Audit (2016)
  - Energy Report
  - Energy Conservation Measures
  - Project selection
- Award of Design development & 60% Design (2020)
  - Development of a Basis of Design report
  - Complete 60% design
  - Establish performance measure
  - Provide a Lump Sump Price

# SFE Rehabilitation Purpose

## Equipment Rehabilitation



Replace aging equipment



## System Resilience



Backup critical plant utilities

# SFE Rehabilitation Purposes

## Equipment Rehabilitation

- The existing system is in poor condition and maintenance needs have increased.
- Four pumps were installed in 1973.
- Two pumps were installed in 1980.
- Two pumps were installed in 1998 and the older pumps were rebuilt.
- Oversized pumps are inefficient and increase pressure on piping.



## System Resilience

- This project will improve the quality of the SFE, enabling it to act as a source of carrier water for chemical treatment and seal water for pump operations.
- A past potable water outage highlighted the risks associated with relying solely on potable water for Wastewater Operations.

# SFE Project Scope

## Pump Station Rehabilitation

---

- Replace pump station
  - Right-size pump station
  - Improve maintenance & operability
  - Increase reliability
- 

## Resilience

---

- SFE Treatment for process water
  - Sulfur dioxide (SO<sub>2</sub>) carrier water
  - Sodium Hypochlorite (NaOH / caustic) source
-


# Scope | SFE Pump Station Rehabilitation

- Six vertical turbine pumps
  - Reduced power use
  - Lower operating pressure
  - 60 MGD capacity (historic usage ~25 MGD)
- Space for two future pumps (if needed)
- Booster pumps to supply high-pressure SFE to incinerators
- Proposed location: north of current SFE pump station





Current SFE pump

# Existing SFE Pumpstation






# Proposed SFE Pumpstation



# Scope | Resilience I of II

## SFE Treatment

- Two cloth disc filters with automatic backwash
- 100,000-gallon storage tank
- New distribution pumps



Future disk filter

# Scope | Resilience II of II

- Sulfur Dioxide (SO<sub>2</sub>) Carrier Water
  - Connection to Detroit River Outflow (DRO) application point
  - New pumps and strainer
- Sodium Hypochlorite (NaOH / caustic) Backup
  - New pumps will feed existing chlorine solution line allowing for both dry and wet weather operations to maintain disinfection through sodium hypochlorite.

# Screened Final Effluent Rehab Timeline and Costs

<b>Builder</b>	NORESCO (with subcontractors)
<b>Designer</b>	Jacobs Engineering (contract with NORESCO)
<b>Phase 1</b>	\$3.9M (60% design)
<b>Phase 2 Amendment</b>	\$100.4M (100% design & construction)
<b>Additional Duration</b>	40 Months (from April 2025 to July 2028)
<b>Total</b>	<b>\$104.3M</b>



Questions????