

HURON TWP EXHIBIT B

Table 1
 Projected Annual Volume and Minimum Annual Volume

Fiscal Year Ending June 30	Projected Annual Volume (Mcf)	Minimum Annual Volume (Mcf)
2009	69,400	34,700
2010	69,400	34,700
2011	62,600	31,300
2012	62,600	31,300
2013	62,600	31,300
2014	62,600	31,300
2015	64,000	32,000
2016	64,000	32,000
2017	64,000	32,000
2018	64,000	32,000
2019	64,000	32,000
2020	65,000	32,500
2021	65,000	32,500
2022	65,000	32,500
2023	65,000	32,500
2024	65,000	32,500
2025	65,000	32,500
2026	65,000	32,500
2027	65,000	32,500
2028	<i>65,000</i>	<i>32,500</i>
2029	<i>65,000</i>	<i>32,500</i>
2030	<i>65,000</i>	<i>32,500</i>
2031	<i>65,000</i>	<i>32,500</i>
2032	<i>65,000</i>	<i>32,500</i>
2033	<i>65,000</i>	<i>32,500</i>
2034	<i>65,000</i>	<i>32,500</i>
2035	<i>65,000</i>	<i>32,500</i>
2036	<i>65,000</i>	<i>32,500</i>
2037	<i>65,000</i>	<i>32,500</i>
2038	<i>65,000</i>	<i>32,500</i>
2039	<i>65,000</i>	<i>32,500</i>

EXHIBIT B

Table 2
Pressure Range and Maximum Flow Rate

Calendar Year (Reopener Schedule in bold type)	Pressure Range (psi) Meter HN-01		Pressure Range (psi) Meter HN-02		Maximum Flow Rate (mgd)	
	<u>Min</u>	<u>Max</u>	<u>Min</u>	<u>Max</u>	<u>Max Day</u>	<u>Peak Hour</u>
2009	NA	NA	34	68	3.88	6.01
2010	NA	NA	34	68	3.88	6.01
2011	60	96	34	68	3.42	5.29
2012	60	96	34	68	3.42	5.29
2013	60	96	34	68	3.42	5.29
2014	60	96	40	75	3.00	4.19
2015	60	96	40	75	3.00	4.19
2016	60	96	40	75	3.00	4.19
2017	60	96	40	75	3.00	4.19
2018	60	96	40	75	3.00	4.19
2019	60	96	40	75	3.10	3.91
2020	60	96	40	75	3.10	3.91
2021	60	96	40	75	3.10	3.91
2022	60	96	40	75	3.10	3.91
2023	60	96	40	75	3.10	3.91
2024	60	96	40	75	3.10	3.91
2025	60	96	40	75	3.10	3.91
2026	60	96	40	75	3.10	3.91
2027	60	96	40	75	3.10	3.91
2028	60	96	40	75	3.10	3.91
2029	60	96	40	75	3.10	3.91
2030	60	96	40	75	3.10	3.91
2031	60	96	40	75	3.10	3.91
2032	60	96	40	75	3.10	3.91
2033	60	96	40	75	3.10	3.91
2034	60	96	40	75	3.10	3.91
2035	60	96	40	75	3.10	3.91
2036	60	96	40	75	3.10	3.91
2037	60	96	40	75	3.10	3.91
2038	60	96	40	75	3.10	3.91

EXHIBIT B

Table 3
Flow Split Assumptions

Meter	Assumed Flow Split (2023-2026)
HN-01	95 – 100 %
HN-02	0 – 5 %

Table 4
Addresses for Notice

If to the Board:	If to Customer:
General Counsel Great Lakes Water Authority 735 Randolph, Suite 1901 Detroit, Michigan 48226	Township Clerk Huron Charter Township 22950 Huron River Drive New Boston, Michigan 48164-9791 Cc: DPW Director