

CITY OF WOODHAVEN
THIRD AMENDED EXHIBIT B

Table 1
Projected Annual Volume and Minimum Annual Volume

Fiscal Year Ending June 30	Projected Annual Volume (Mcf)	Minimum Annual Volume (Mcf)
2009	95,000	47,500
2010	95,000	47,500
2011	90,000	45,000
2012	90,000	45,000
2013	90,000	45,000
2014	77,000	38,500
2015	77,000	38,500
2016	77,000	38,500
2017	77,000	38,500
2018	77,000	38,500
2019	60,800	30,400
2020	60,800	30,400
2021	60,800	30,400
2022	60,800	30,400
2023	60,800	30,400
2024	<i>60,800</i>	<i>30,400</i>
2025	<i>60,800</i>	<i>30,400</i>
2026	<i>60,800</i>	<i>30,400</i>
2027	<i>60,800</i>	<i>30,400</i>
2028	<i>60,800</i>	<i>30,400</i>
2029	<i>60,800</i>	<i>30,400</i>
2030	<i>60,800</i>	<i>30,400</i>
2031	<i>60,800</i>	<i>30,400</i>
2032	<i>60,800</i>	<i>30,400</i>
2033	<i>60,800</i>	<i>30,400</i>
2034	<i>60,800</i>	<i>30,400</i>
2035	<i>60,800</i>	<i>30,400</i>
2036	<i>60,800</i>	<i>30,400</i>
2037	<i>60,800</i>	<i>30,400</i>
2038	<i>60,800</i>	<i>30,400</i>

THIRD AMENDED EXHIBIT B

Table 2
Pressure Range and Maximum Flow Rate

Calendar Year	Pressure Range (psi)		Pressure Range (psi)		Maximum Flow Rate (mgd)	
	Meter WO-01		Meter WO-02		<u>Max Day</u>	<u>Peak Hour</u>
	<u>Min</u>	<u>Max</u>	<u>Min</u>	<u>Max</u>		
2008	56	79	54	76	5.30	8.66
2009	56	79	54	76	5.30	8.66
2010	56	79	54	76	4.80	8.00
2011	56	79	54	76	4.80	8.00
2012	56	79	54	76	4.80	8.00
2013	56	79	54	76	4.80	8.00
2014	56	79	54	76	4.80	8.00
2015	56	79	54	76	4.80	8.00
2016	56	79	54	76	4.80	8.00
2017	56	79	54	76	4.80	8.00
2018	56	79	54	76	3.24	5.12
2019	56	79	54	76	3.24	5.12
2020	56	79	54	76	3.24	5.12
2021	56	79	54	76	3.24	5.12
2022	56	79	54	76	3.24	5.12
2023	56	79	54	76	3.24	5.12
2024	56	79	54	76	3.24	5.12
2025	56	79	54	76	3.24	5.12
2026	56	79	54	76	3.24	5.12
2027	56	79	54	76	3.24	5.12
2028	56	79	54	76	3.24	5.12
2029	56	79	54	76	3.24	5.12
2030	56	79	54	76	3.24	5.12
2031	56	79	54	76	3.24	5.12
2032	56	79	54	76	3.24	5.12
2033	56	79	54	76	3.24	5.12
2034	56	79	54	76	3.24	5.12
2035	56	79	54	76	3.24	5.12
2036	56	79	54	76	3.24	5.12
2037	56	79	54	76	3.24	5.12

THIRD AMENDED EXHIBIT B

Table 3
Flow Split Assumptions

Meter	Assumed Flow Split (2018-2022)
WO-01	10 – 30 %
WO-02	70 – 90 %

Table 4
Addresses for Notice

If to GLWA: General Counsel Great Lakes Water Authority 735 Randolph Street, Suite 1901 Detroit, Michigan 48226	If to Customer: City Administrator City of Woodhaven 21869 West Road Woodhaven, Michigan 48183-3297 cc: City Clerk
--	--