

MAYFIELD TWP EXHIBIT B

Table 1
 Projected Annual Volume and Minimum Annual Volume

Fiscal Year Ending June 30	Projected Annual Volume (Mcf)	Minimum Annual Volume (Mcf)
2017	482	241
2018	482	241
2019	590	295
2020	1200	600
2021	1200	600
2022	1200	600
2023	1200	600
2024	<i>1200</i>	<i>600</i>
2025	<i>1200</i>	<i>600</i>
2026	<i>1200</i>	<i>600</i>
2027	<i>1200</i>	<i>600</i>
2028	<i>1200</i>	<i>600</i>
2029	<i>1200</i>	<i>600</i>
2030	<i>1200</i>	<i>600</i>
2031	<i>1200</i>	<i>600</i>
2032	<i>1200</i>	<i>600</i>
2033	<i>1200</i>	<i>600</i>
2034	<i>1200</i>	<i>600</i>
2035	<i>1200</i>	<i>600</i>
2036	<i>1200</i>	<i>600</i>
2037	<i>1200</i>	<i>600</i>
2038	<i>1200</i>	<i>600</i>
2039	<i>1200</i>	<i>600</i>
2040	<i>1200</i>	<i>600</i>
2041	<i>1200</i>	<i>600</i>
2042	<i>1200</i>	<i>600</i>
2043	<i>1200</i>	<i>600</i>
2044	<i>1200</i>	<i>600</i>
2045	<i>1200</i>	<i>600</i>
2046	<i>1200</i>	<i>600</i>

EXHIBIT B

Table 2
Pressure Range and Maximum Flow Rate

Calendar Year (Reopener Schedule in bold type)	Pressure Range (psi)		Maximum Flow Rate (mgd)	
	Meter MF-01		<u>Max Day</u>	<u>Peak Hour</u>
	<u>Min</u>	<u>Max</u>		
2016	55	75	0.02	0.04
2017	55	75	0.02	0.05
2018	55	75	0.03	0.07
2019	55	75	0.040	0.070
2020	55	75	0.040	0.070
2021	55	75	0.040	0.070
2022	55	75	0.040	0.070
2023	55	75	0.040	0.070
2024	55	75	0.040	0.070
2025	55	75	0.040	0.070
2026	55	75	0.040	0.070
2027	55	75	0.040	0.070
2028	55	75	0.040	0.070
2029	55	75	0.040	0.070
2030	55	75	0.040	0.070
2031	55	75	0.040	0.070
2032	55	75	0.040	0.070
2033	55	75	0.040	0.070
2034	55	75	0.040	0.070
2035	55	75	0.040	0.070
2036	55	75	0.040	0.070
2037	55	75	0.040	0.070
2038	55	75	0.040	0.070
2039	55	75	0.040	0.070
2040	55	75	0.040	0.070
2041	55	75	0.040	0.070
2042	55	75	0.040	0.070
2043	55	75	0.040	0.070
2044	55	75	0.040	0.070
2045	55	75	0.040	0.070

EXHIBIT B

Table 3
Flow Split Assumptions

Meter	Assumed Flow Split (2019-2022)
MF-01	100 %

Table 4
Addresses for Notice

If to the Board:	If to Customer:
General Counsel Great Lakes Water Authority 735 Randolph, Suite 1901 Detroit, Michigan 48226	Supervisor Mayfield Township 1900 N. Saginaw Road Lapeer, Michigan 48446 cc: Township Clerk