

MAYFIELD TOWNSHIP

FIRST AMENDED EXHIBIT B

Table 1  
 Projected Annual Volume and Minimum Annual Volume

Fiscal Year Ending June 30	Projected Annual Volume (Mcf)	Minimum Annual Volume (Mcf)
2017	<b>482</b>	<b>241</b>
2018	<b>482</b>	<b>241</b>
2019	<b>590</b>	<b>295</b>
2020	<b>660</b>	<b>330</b>
2021	<b>740</b>	<b>370</b>
2022	740	370
2023	740	370
2024	740	370
2025	740	370
2026	740	370
2027	740	370
2028	740	370
2029	740	370
2030	740	370
2031	740	370
2032	740	370
2033	740	370
2034	740	370
2035	740	370
2036	740	370
2037	740	370
2038	740	370
2039	740	370
2040	740	370
2041	740	370
2042	740	370
2043	740	370
2044	740	370
2045	740	370
2046	740	370

FIRST AMENDED EXHIBIT B

Table 2  
Pressure Range and Maximum Flow Rate

Calendar Year	Pressure Range (psi)		Maximum Flow Rate (mgd)	
	Meter MF-01		Max Day	Peak Hour
	Min	Max		
2016	<b>55</b>	<b>75</b>	<b>0.02</b>	<b>0.04</b>
2017	<b>55</b>	<b>75</b>	<b>0.02</b>	<b>0.05</b>
2018	<b>55</b>	<b>75</b>	<b>0.03</b>	<b>0.07</b>
2019	<b>55</b>	<b>75</b>	<b>0.03</b>	<b>0.07</b>
2020	<b>55</b>	<b>75</b>	<b>0.03</b>	<b>0.07</b>
2021	55	75	0.03	0.07
2022	55	75	0.03	0.07
2023	55	75	0.03	0.07
2024	55	75	0.03	0.07
2025	55	75	0.03	0.07
2026	55	75	0.03	0.07
2027	55	75	0.03	0.07
2028	55	75	0.03	0.07
2029	55	75	0.03	0.07
2030	55	75	0.03	0.07
2031	55	75	0.03	0.07
2032	55	75	0.03	0.07
2033	55	75	0.03	0.07
2034	55	75	0.03	0.07
2035	55	75	0.03	0.07
2036	55	75	0.03	0.07
2037	55	75	0.03	0.07
2038	55	75	0.03	0.07
2039	55	75	0.03	0.07
2040	55	75	0.03	0.07
2041	55	75	0.03	0.07
2042	55	75	0.03	0.07
2043	55	75	0.03	0.07
2044	55	75	0.03	0.07
2045	55	75	0.03	0.07

FIRST AMENDED EXHIBIT B

Table 3  
Flow Split Assumptions

<b>Meter</b>	<b>Assumed Flow Split (2018-2020)</b>
MF-01	100 %

Table 4  
Addresses for Notice

<b>If to GLWA:</b>	<b>If to Customer:</b>
General Counsel Great Lakes Water Authority 735 Randolph Street, Suite 1901 Detroit, Michigan 48226	Supervisor Mayfield Township 1900 N. Saginaw Road Lapeer, Michigan 48446  cc: Township Clerk