

LENOX TWP

EXHIBIT B

Table 1
Projected Annual Volume and Minimum Annual Volume

Fiscal Year Ending June 30	Projected Annual Volume (Mcf)	Minimum Annual Volume (Mcf)
2009	17,500	8,750
2010	17,500	8,750
2011	15,300	7,650
2012	15,300	7,650
2013	15,300	7,650
2014	15,300	7,650
2015	15,300	7,650
2016	15,300	7,650
2017	15,300	7,650
2018	15,300	7,650
2019	15,300	7,650
2020	16,000	8,000
2021	16,000	8,000
2022	16,000	8,000
2023	16,000	8,000
2024	<i>16,000</i>	<i>8,000</i>
2025	<i>16,000</i>	<i>8,000</i>
2026	<i>16,000</i>	<i>8,000</i>
2027	<i>16,000</i>	<i>8,000</i>
2028	<i>16,000</i>	<i>8,000</i>
2029	<i>16,000</i>	<i>8,000</i>
2030	<i>16,000</i>	<i>8,000</i>
2031	<i>16,000</i>	<i>8,000</i>
2032	<i>16,000</i>	<i>8,000</i>
2033	<i>16,000</i>	<i>8,000</i>
2034	<i>16,000</i>	<i>8,000</i>
2035	<i>16,000</i>	<i>8,000</i>
2036	<i>16,000</i>	<i>8,000</i>
2037	<i>16,000</i>	<i>8,000</i>
2038	<i>16,000</i>	<i>8,000</i>
2039	<i>16,000</i>	<i>8,000</i>

EXHIBIT B

Table 2
Pressure Range and Maximum Flow Rate

Calendar Year (Reopener Schedule in bold type)	Pressure Range (psi) Meter LX-01		Pressure Range (psi) Meter LX-02		Maximum Flow Rate (mgd)	
	<u>Min</u>	<u>Max</u>	<u>Min</u>	<u>Max</u>	<u>Max Day</u>	<u>Peak Hour</u>
2009	59	143	39	142	0.56	1.85
2010	59	143	39	142	0.56	1.85
2011	70	143	70	142	0.53	0.85
2012	70	143	70	142	0.53	0.85
2013	70	143	70	142	0.53	0.85
2014	70	143	70	142	0.487	0.781
2015	70	143	70	142	0.487	0.781
2016	70	143	70	142	0.487	0.781
2017	70	143	70	142	0.487	0.781
2018	70	143	70	142	0.487	0.781
2019	70	143	70	142	0.510	0.704
2020	70	143	70	142	0.510	0.704
2021	70	143	70	142	0.510	0.704
2022	70	143	70	142	0.510	0.704
2023	70	143	70	142	0.510	0.704
2024	70	143	70	142	0.510	0.704
2025	70	143	70	142	0.510	0.704
2026	70	143	70	142	0.510	0.704
2027	70	143	70	142	0.510	0.704
2028	70	143	70	142	0.510	0.704
2029	70	143	70	142	0.510	0.704
2030	70	143	70	142	0.510	0.704
2031	70	143	70	142	0.510	0.704
2032	70	143	70	142	0.510	0.704
2033	70	143	70	142	0.510	0.704
2034	70	143	70	142	0.510	0.704
2035	70	143	70	142	0.510	0.704
2036	70	143	70	142	0.510	0.704
2037	70	143	70	142	0.510	0.704
2038	70	143	70	142	0.510	0.704

EXHIBIT B

Table 3
Flow Split Assumptions

Meter	Assumed Flow Split (2019-2022)
LX-01	50 – 100 %
LX-02	0 – 55 %

Table 4
Addresses for Notice

If to the Board: General Counsel Great Lakes Water Authority 735 Randolph, Suite 1901 Detroit, Michigan 48226	If to Customer: Township Clerk Lenox Township 63775 Gratiot Lenox, Michigan 48050 Cc: DPW Superintendent
--	--