



Legislation Details (With Text)

File #:	2021-002	Version:	1	Name:	
Type:	Resolution	Status:		Passed	
File created:	1/5/2021	In control:		Board of Directors	
On agenda:	2/24/2021	Final action:		2/24/2021	
Title:	Contract No. 2001051 Southwest Water Treatment Plant SCADA Network Upgrade CIP# 170302 / BCE Score: N/A				
Sponsors:	Cheryl Porter, Terry Daniel				
Indexes:	Water Operations				
Code sections:					
Attachments:	1. 2001051 Procurement Report, 2. 2001051 Cost Tabulation, 3. 2001051 Vendor Response Follow-up				

Date	Ver.	Action By	Action	Result
2/24/2021	1	Board of Directors	Approved	Pass

Contract No. 2001051
Southwest Water Treatment Plant SCADA Network Upgrade
CIP# 170302 / BCE Score: N/A

Agenda of: February 24, 2021
Item No.: **2021-002**
Amount: \$7,891,696.00

TO: The Honorable
Board of Directors
Great Lakes Water Authority

FROM: Sue F. McCormick
Chief Executive Officer
Great Lakes Water Authority

DATE: January 6, 2021

RE: **Contract No. 2001051**
Southwest Water Treatment Plant SCADA Network Upgrade
Vendor: Burns and McDonnell Michigan, Inc.

MOTION

Upon recommendation of Cheryl Porter, Chief Operating Officer - Water and Field Services, the Board of Directors (Board) of the Great Lakes Water Authority (GLWA), authorizes the Chief

Executive Officer (CEO) to **enter into Contract No. 2001051 “Southwest Water Treatment Plant SCADA Network Upgrade” with Burns and McDonnell Michigan, Inc., at a cost not to exceed \$7,891,696.00 for a duration of 730 days;** and authorizes the CEO to take such other action as may be necessary to accomplish the intent of this vote.

BACKGROUND

GLWA recognizes the importance of its automation systems to achieve its continued vision of reliable and quality water service to its member partners. Therefore, a rigorous and detailed condition assessment of the existing instrumentation and control (I&C) and supervisory control and data acquisition (SCADA) assets was performed at each of the water treatment facilities under contract CS-108. These assessments identified several opportunities for improvement in the areas of automation and system monitoring at all five of the GLWA water treatment plants.

In addition to identifying improvements at the water treatment plants, the condition assessment developed design governance documents to be used at all five water plants to ensure uniform and consistent systems are being designed and constructed throughout the treatment plants.

JUSTIFICATION

The condition assessment for Southwest Water Treatment Plant for this Design Build project showed that 97% of the critical SCADA assets had reached the end of useful life. The improvements identified in the assessment centered on replacement of these assets, removal of an unsupported/obsolete control communication protocol (Device Net) and the implementation of a new process control network based off the GLWA’s SCADA governance standards. The implementation of these improvements would ensure the reliability of the water treatment process at Southwest Water Treatment Plant for the next 20 years.

FINANCIAL PLAN IMPACT

Summary: Sufficient funds are provided in the financial plan for this project.

Funding Source: Water Construction Fund

Cost Center: Water Engineering

Expense Type: Construction (5519-882111.000-616900-170302)

Estimated Cost by Year and Related Estimating Variance: See table below.

Fiscal Year

FY 2021 Planned Spend	\$ 1,788,000.00
-----------------------	-----------------

FY 2022 Planned Spend	3,606,000.00
-----------------------	--------------

FY 2023 Planned Spend	<u>3,606,000.00</u>
-----------------------	---------------------

Financial Plan Estimate	\$ 9,000,000.00
-------------------------	-----------------

Proposed Contract Award		<u>7,891,696.00</u>	
Estimating	Variance	\$	1,108,304.00

Amounts above as per the Draft #2 2022-2026 CIP. A budget amendment will be prepared to return the positive estimating variance back to the Program associated with this proposed contract.

SAVINGS, COST OPTIMIZATION, AND REVENUE ENHANCEMENT IMPACT

This contract is for the SCADA network upgrade at Southwest Water Treatment Plant. Cost savings are not determinable at this time.

COMMITTEE REVIEW

This item is being presented directly to the full Board of Directors.

SHARED SERVICES IMPACT

This item does not impact the shared services agreement between GLWA and DWSD.